

November 19, 2025

SPOKANE TRANSIT AUTHORITY
AMENDMENT TO REQUEST FOR PROPOSALS
RFP #2025-11080
HPT MARKERS AND LIGHT POLES

AMENDMENT NO. 2

This Amendment consists of this cover page and one attachment.

- 1) Attachment 1 - Questions and Answers spreadsheet.

This concludes the Questions and Answers period for this RFP.

This Amendment is hereby made a part of the Request for Proposals document to the same extent as though it were originally included therein. All Proposers shall acknowledge receipt and understanding of this Amendment by completing the information required on Attachment A, Proposal Response Form, and returning the signed page with their proposal on or before the proposal due date.

Josh Wood

Procurement Coordinator

Attachment 1
Spokane Transit Authority
Amendment #2 to Request for Proposals
RFP #2025-11080
HPT Markers and Light Poles

Question #	Document Section	Page Number	Question	STA Response
1	Att. F, FSI-08-12-301, FSI-08-12-301-01 thru FSI-08-12-301-05	80-86	Request for Substitution: Substituion request for FSI extruded aluminum part (FSI-08-12-301) to a custom milled 1/2" x 1.5" aluminum flat bar with 1" x 1" milled aluminum square bar and .125" brake formed aluminum frame for removable map.	The intent is for the contractor to provide a final assembly that meets the intents and requirements of the drawings. Where necessary, it is the contractor’s responsibility to utilize their fabrication expertise to design custom assemblies, fabricated parts, etc. that will be compatible with the intended functionality and finish dimensions of the assembly. For the map case specifically, the functionality and the general geometry of the assembly, and specifically the hinges and hinge attachments, need to be maintained in order to provide the required access to the interior of the marker. Therefore, for the purpose of submitting a proposal, contractor may include their requested substitution to include specifications and a sketch of proposed substitution with their proposal. STA is not in a position to approve or deny this substitution request until contractor provides a fabrication of a full mock-up (prototype) of each amenity for inspection and approval by STA. STA relies on the contractor to determine a suitable solution for the part in question.